

Pirrello, Jo Ann (RER)

From: Fernandez, Yanek (PWWM)
Sent: Wednesday, June 03, 2015 11:17 AM
To: Pirrello, Jo Ann (RER)
Subject: FW: C2015077260; 14201 SW 8 Terrace

fyi

From: Fernandez, Yanek (PWWM)
Sent: Monday, June 01, 2015 2:31 PM
To: eileen.mursuli@yahoo.com
Cc: Cohen, Jeff (PWWM); Faulkner, Brenda (PWWM); Shen, Joan (PWWM)
Subject: C2015077260; 14201 SW 8 Terrace

Dear Mrs. Mursuli,

Please be advised that the Public Works and Waste Management Department has conducted an analysis of your proposed fence, and has unfortunately determined that a waiver of Section 33-11(c) of the Code of Miami-Dade County, which addresses safe sight distance triangles (SSDT), cannot be granted in your case, because SW 142 Avenue is not a local road, and your proposal fence will obstruct the view of motorists approaching SW 142 Avenue and SW 8 Terrace. The fence should be proposed outside of the SSDT.

Best Regards,

Yanek Fernandez, P.E., PTP, PTOE

Miami-Dade Public Works and Waste Management
111 NW First Street, Suite 1510
Miami, FL 33128
Phone: (305)375-1847
Fax: (305)679-7738
yanek@miamidade.gov

Miami Dade County Department of Regulatory And Economic Resources

0000696277 - 6/4/2015 8:18:57 AM

c2015077260.pdf

<u>Examiner</u>	<u>Date Time Stamp</u>	<u>Disp.</u>	<u>Trade</u>	<u>Stamp Name</u>
JoAnn Pirrello	6/4/2015 8:17:16 AM	A	ZONE	Reference document